

Certificates




Insulation

PYROCOMB® TCX

European Technical Assessment No. ETA-12/0182 issued 07-07-2017





Be it in a residential building or an industrial complex – OBO has the appropriate solution for fireproof electrical installations. Our tested and certified fire protection systems cover all the relevant fire protection guidelines and provide you with an electrical installation that really serves its purpose. We will be happy to provide you with more details – on our website or personally.





Approval body for construction products and types of construction

Bautechnisches Prüfamt

An institution established by the Federal and Laender Governments



European Technical Assessment

ETA-12/0182 of 7 July 2017

English translation prepared by DIBt - Original version in German language

General Part

Technical Assessment Body issuing the European Technical Assessment:

Trade name of the construction product

Product family

to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

This version replaces

Deutsches Institut für Bautechnik

TCX / TCX-L

pipe collar

OBO BETTERMANN GmbH & Co. KG

Hüingser Ring 52 58710 Menden DEUTSCHLAND

Herstellwerk K

12 pages including 8 annexes which form an integral part of this assessment

Guideline for European technical approval of "Fire Stopping and Fire Sealing Products", ETAG 026 Part 2: "Penetration Seals".

used as European Assessment Document (EAD) according to Article 66 Paragraph 3 of Regulation (EU) No 305/2011.

ETA-12/0182 issued on 24 April 2012



European Technical Assessment ETA-12/0182 English translation prepared by DIBt

Page 2 of 12 | 7 July 2017

The European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

Z24100.17 8.11.04-13/17



European Technical Assessment ETA-12/0182 English translation prepared by DIBt

Page 3 of 12 | 7 July 2017

Specific Part

1 Technical description of the product

"TCX / TCX-L" is a pipe collar consisting of a pipe collar enclosure and a fire-protective inlay.

The pipe collar enclosure shall be made of steel sheet and be sufficiently protected against corrosion. The fire-protective inlay shall be made of an intumescent material which expands under heat exposure.

The pipe collar shall have the dimensions stated in Annexes 2 to 4.

Detailed specifications and fire safety related performance criteria for the construction products are given in Annex 1.

NOTE:

The characteristics listed are suitable both for identifying the construction products as well as for performing the manufacturer's factory production control.

2 Specification of the intended use in accordance with the applicable European Assessment Document

"TCX / TCX-L" is designed to form part of a pipe penetration seal for plastic pipes.

Pipe penetration seals are used to seal openings in fire resistant walls and floors, which are penetrated by pipes. Their aim is to preserve the walls' or floors' fire resistance in the area of the penetrations.

Within the scope of this ETA the fire resistance of a pipe seal was demonstrated that consisted of two pipes collars (for wall installations) or one pipe collar (for floor installations) and a joint sealing.

The fire-protective inlay of "TCX / TCX-L" fulfils the requirements of use category X (see EOTA TR 024); that means that the materials can be exposed to the conditions in interiors with and without moisture loads and external weathering, without expecting significant changes in fire protection characteristics.

More detailed information and data on the verified penetration seals are given in Annexes 5 to 8. The performances given in Section 3 relate exclusively to these penetration seals (e.g. with respect to the design and arrangement of the penetration seals' components and the type and position of the services).

3 Performance of the product and references to the methods used for its assessment

3.1 Intended use: use in penetration seals

| Essential characteristic (BWR 2) | Performance | | |
|---|--|--|--|
| Reaction to fire | Pipe collar enclosure: class A1 in accordance with commission decision 96/603/EC (of the current version) | | |
| | Intumescent Inlay: class E in accordance with EN 13501-1 | | |
| Fire resistance of a penetration seal incorporating the product | The fire resistance depends on the construction/ installation of the penetration seal and on the other components incorporated in the penetration seal. Details on the verified penetration seals and the related fire resistance classes are given in Annexes 1 to 8. | | |

Z24100.17 8.11.04-13/17



European Technical Assessment ETA-12/0182 English translation prepared by DIBt

Page 4 of 12 | 7 July 2017

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with the guideline for European technical approval of "Fire Stopping and Fire Sealing Products", ETAG 026 Part 2: "Penetration Seals", August 2011, used as European Assessment Document (EAD), the applicable European legal act is: 1999/454/EC.

The system to be applied is: 1

Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

Issued in Berlin on 7 July 2017 by Deutsches Institut für Bautechnik

Prof. Gunter Hoppe Head of Department beglaubigt: Nadja Bisemeier

Z24100.17 8.11.04-13/17



The factory manufactured construction product pipe collar "TCX / TCX-L" consists of a pipe collar steel housing and an insert of an intumescent building material which is incorporated in multiple layers in the pipe collar housing.

Properties and performance criteria of the components of the construction products

| Component | Description |
|-----------------------|---|
| "Pipe collar housing" | Dimensions: See Annexes 2 to 4 |
| | Material: Sheet steel |
| | Classification of fire behavior: Class A1 according to the commission |
| | decision 96/603/EC (of the current version) |
| "Insert" | Dimensions: See Annexes 2 to 4 |
| | Material: Intumescent building material according to ETA-10/0117 |
| | Classification of the fire behavior according to EN 13501-1: Class E |

The properties listed can be used both for the identification of the construction product and for the implementation of the factory production control of the manufacturer.

Implementation details for the factory production control are included in the inspection plan.

Performances of penetration seals, comprising the construction product "TCX / TCX-L"

| | Essential requirement | Test method | Construction oft he sample | Performance acc. to EN-13501-2 |
|---|-----------------------|-------------|---|--------------------------------------|
| 1 | Resistance to fire | EN 1366-3 | 100 mm thick rigid wall; design and layout of the penetration seal according to Annex 5* | EI 240-U/C |
| 2 | Resistance to fire | EN 1366-3 | 100 mm thick flexible wall; design and layout of the penetration seal according to Annex 6* | EI 120-U/C |
| 3 | Resistance to fire | EN 1366-3 | 300 mm thick rigid floor; design and layout of the penetration seal according to Annex 7* | EI 180-U/C bzw. E 240 U/C |
| 4 | Resistance to fire | EN 1366-3 | 150 mm thick rigid floor; design and layout of the penetration seal according to Annex 8* | EI 120-U/U |


^{*} The illustrations are without guarantee for completeness.

The use of the construction product "TCX / TCX-L" in penetration seals shall be in accordance with national requirements for planning, design and execution and in accordance with the installation instruction of the manufacturer.

The tested/ illustrated seals are only examples for the use.

| Annex 1 |
|---------|
| |






Pipe collar "TCX / TCX-L" in the dimensions TCX-L

| dA [mm] | d [mm] | D [mm] | b [mm] | t [mm] | H [mm] | P [Stck] | h [mm] | a [mm] | B [mm] |
|---------|--------|--------|--------|--------|--------|----------|--------|-------------|--------|
| 32 | 38 | 47 | 4,6 | 0,6 | 26,0 | 2 | 25,0 | 4,0 -0/+0,8 | 9,0 |
| 40 | 46 | 55 | 4,6 | 0,6 | 26,0 | 2 | 25,0 | 4,0 -0/+0,8 | 9,0 |
| 50 | 56 | 65 | 4,6 | 0,6 | 26,0 | 2 | 25,0 | 4,0 -0/+0,8 | 9,0 |
| 63 | 69 | 82 | 6,6 | 0,6 | 26,0 | 4 | 25,4 | 6,0 -0+1,0 | 9,0 |
| 75 | 81 | 94 | 6,6 | 0,6 | 26,0 | 4 | 25,4 | 6,0 -0+1,0 | 9,0 |
| 90 | 96 | 114 | 9,0 | 1,0 | 26,6 | 4 | 25,4 | 8,0 -0+1,5 | 9,0 |
| 110 | 116 | 134 | 9,0 | 1,0 | 26,6 | 4 | 25,4 | 8,0 -0+1,5 | 9,0 |
| 125 | 132 | 150 | 9,0 | 1,0 | 26,6 | 4 | 38,0 | 10 -0+2,0 | 9,0 |
| 140 | 144 | 168 | 12 | 1,0 | 40,0 | 4 | 38,0 | 10 -0+2,0 | 9,0 |
| 160 | 164 | 188 | 12 | 1,0 | 40 | 4 | 38,0 | 10 -0+2,0 | 9,0 |

| TCX / TCX-L | |
|---|---------|
| Design of the pipe collar in the size TCX-L | Annex 2 |
| | |

Z23697.17 8.11.04-13/17






| dA [mm] | d [mm] | D [mm] | b [mm] | t [mm] | H [mm] | P [Stck] | h [mm] | a [mm] | B [mm] |
|---------|--------|--------|--------|--------|--------|----------|--------|------------------|--------|
| 32 | 36 | 50 | 7,0 | 0,6 | 26,0 | 2 | 25,4 | 6,4 <u>+</u> 0,5 | 6,0 |
| 40 | 44 | 58 | 7,0 | 0,6 | 26,0 | 2 | 25,4 | 6,4 <u>+</u> 0,5 | 6,0 |
| 50 | 54 | 68 | 7,0 | 0,6 | 26,0 | 2 | 25,4 | 6,4 <u>+</u> 0,5 | 6,0 |
| 63 | 67 | 94 | 13,5 | 0,6 | 26,0 | 4 | 25,4 | 12,8 ±1,0 | 6,0 |
| 75 | 79 | 106 | 13,5 | 0,6 | 26,0 | 4 | 25,4 | 12,8 ±1,0 | 6,0 |
| 90 | 94 | 132 | 18,3 | 1,1 | 26,6 | 4 | 25,4 | 17,1 ±1,0 | 9,0 |
| 110 | 114 | 155 | 20,5 | 1,1 | 26,6 | 4 | 25,4 | 19,2 ±1,5 | 9,0 |
| 125 | 129 | 172 | 20,5 | 1,1 | 40,0 | 4 | 38,1 | 19,2 -0/+1,5 | 9,0 |
| 140 | 144 | 200 | 28,0 | 1,1 | 40,0 | 4 | 38,1 | 25,6 -0/+2,0 | 9,0 |
| 160 | 164 | 220 | 28,0 | 1,1 | 40,0 | 4 | 38,1 | 25,6 -0/+2,0 | 9,0 |
| 180 | 184 | 264 | 40,0 | 1,5 | 40,0 | 8 | 38,1 | 38,4 ± 3,0 | 9,0 |
| 200 | 204 | 284 | 40,0 | 1,5 | 40,0 | 8 | 38,1 | 38,4 ± 3,0 | 9,0 |

| TCX / TCX-L | |
|---|---------|
| Design of the pipe collar in the size TCX | Annex 3 |
| | |







| dA [mm] | d [mm] | D [mm] | b [mm] | t [mm] | H [mm] | P [Stck] | h [mm] | a [mm] | B [mm] |
|---------|--------|--------|--------|-----------|--------|----------|--------|-------------------|--------|
| 225 | 239 | 328 | 44,5 | 1,5 / 1,0 | 51,5 | 10 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |
| 250 | 264 | 353 | 44,5 | 1,5 / 1,0 | 51,5 | 10 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |
| 280 | 289 | 378 | 44,5 | 1,5 / 1,0 | 51,5 | 12 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |
| 300 | 314 | 403 | 44,5 | 1,5 / 1,0 | 51,5 | 12 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |
| 315 | 328 | 417 | 44,5 | 1,5 / 1,0 | 51,5 | 12 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |
| 355 | 370 | 459 | 44,5 | 1,5 / 1,0 | 51,5 | 12 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |
| 400 | 415 | 504 | 44,5 | 1,5 / 1,0 | 51,5 | 12 | 50 | 42,0 <u>+</u> 3,0 | 8,0 |

| TCX / TCX-L | |
|---|---------|
| Design of the pipe collar in the size TCX | Annex 4 |
| | |










CW 50x50x0,6 and UW 50x40x0,6 according to DIN 18182-01 2 x 12,5 mm gypsum board F / EN 520-G25/2,5 according to EN 520 two layers on both sides 40 mm mineral wool insulation, p 100kg/m³, melting point ≥ 1000° C, A1 according to EN 13501-1

| | Pi | pe | |
|--------------|--------|--------|---------------------|
| Type of pipe | Ø [mm] | s [mm] | Pipe collar size |
| Coolfit | 180 | / | TCX 180 |

| TCX / TCX-L | |
|--|---------|
| Example for a pipe sealing of fire resistance class EI 120-U/C, using pipe collar "TCX / TCX-L", in the size of TCX, ø 180 | Annex 6 |





Blanket

1 Aerated concrete blocks d = 150 mm; $600 - 650 \text{ kg/m}^3$ 2 Aerated concrete panels d = 150 mm; $450 - 500 \text{ kg/m}^3$

| | Pi | pe | |
|--------------|--------|--------|---------------------|
| Type of pipe | Ø [mm] | s [mm] | Pipe collar size |
| PVC | 400 | 11,7 | TCX 400 |

Fixation:

Screws MMS-P 7,5 x 45


10

metal multipurpose anchors 8 x 38

| TCX / TCX-L | |
|---|---------|
| Example for a pipe sealing of fire resistance class EI 180-U/C or E 240-U/C, using pipe collar "TCX / TCX-L", in the size of TCX, ø 400 | Annex 7 |

Z23697.17 8.11.04-13/17





Blanket
Aerated concrete according to EN 1366-3


| Pipe | | | | |
|--------------|--------|--------|---------------------|--|
| Type of pipe | Ø [mm] | s [mm] | Pipe collar size | |
| PP | 110 | 2,7 | TCX-L 110 | |

Fixation: Screws MMS-P 7,5 x 45

01

metal multipurpose anchors 8 x 38

| TCX / TCX-L | |
|--|---------|
| Example for a pipe sealing of fire resistance class EI 120-U/U, using pipe collar "TCX / TCX-L", in the size of TCX-L, Ø 110 | Annex 8 |



OBO Bettermann Holding GmbH & Co. KG

P.O. Box 1120 58694 Menden GERMANY

Customer Service

Tel.: +49 23 73 89-13 00 Fax: +49 23 73 89-71442

toi@obo.de

www.obo-bettermann.com

OBO Bettermann



BETTERMANN